



PLAN VIEW
NOT TO SCALE

NOTES:

1. DETAIL SHALL BE IN ACCORDANCE WITH CITY OF SCOTTSDALE, ARIZONA DETAIL #2351.
2. PAINT TO MATCH BUILDING.
3. BACKFLOW SHALL BE EQUIPPED WITH A TAMPER SWITCH WIRED TO FIRE CONTROL PANEL INSIDE BUILDING.
4. FDC PORTS TO BE EQUIPPED WITH KNOX 2.5" LOCKING FDC PLUG WITH SWIVEL-GUARD MODEL NO. 3041.

CITY OF TOLLESON
ARIZONA

**FIRELINE BACKFLOW
PREVENTION ASSEMBLY**

11-17-2014